

TDSP	Major Transmission Element (MTE)	Equip. Type	kV	Congestion Year	Congestion Month	Contingency	Overload	Source	Outage Type	Cancelled	Removal Request	Requestor	Reason for Removal	Decision	Discussion Items
ONCOR	Anna Sw - Valley SES	LN	345	2015	10	DCKT Valley South to Paris Sw and Valley SES 345 kV	Payne Sw - Memc West Tap 138 kV	2	Planned	Y					
ONCOR	Argyle Bus #1	BUS	138	2015	8	Jim Christal Sub to West Denton 138 kV	Pockrus Sub - Teasely Sub 138 kV	2	Planned	Y					
ONCOR	Calmont Sw - ... - Eagle Mountain (6190)	LN	138	2015	6, 7	DCKT Eagle Mountain SES - Parker Switch and Hicks Switch 345kv	Calmont Switch - Western Hills 138 kV (6185)	1	Planned/Forc	N					
ONCOR	Cedar Crest Switch East Bus	BUS	138	2015	9	DCKT Mountain Creek to Cedar Hill Sw and Westmoreland 138 kV	West Levee Sw - Dallas West 138 kV	2	Planned	N	Discussion Item				Oncor believes this congestion occurs only when Normally Open West Levee CB 025 is closed. Cedar Crest East Bus is only a HITE if CB 025 is closed during the outage.
ONCOR	Cedar Hill Sw - Mountain Creek	LN	138	2015	9	Polk Street to Oak Cliff South (6) 138 KV	Cedar Crest Switch - Oak Cliff South 138kV	1, 2	Planned	N					
ONCOR	Centerville Road Sw - Forney Sw	LN	345	2015	1	DCKT Royse Sw to Forney Sw 345 kV	Forney Sw AXFMR3 345/138kV	2	Planned	N					
ONCOR	Centerville Road Sw - Garland Road (3240_A)	LN	138	2015	9	DCKT Greenville Ave Sw to Parkdale Sw 138 kV	Centerville Road Sw - Garland Road (3250_A)	2	Planned	N					
ONCOR	Cockrell Hill - Mountain Creek	LN	138	2015	5	DCKT Norwood Sw to Liggett Sw and Cedar Hill Sw 345 kV	Trinity River Authority - Mountain Creek 138 kV	2	Planned	Y					
ONCOR	Cosden - Morgan Creek	LN	138	2015	2, 4	Barber Lake Sw to Morgan Creek 138 kV (14030 or 14035)	Barber Lake Sw - Morgan Creek 138 kV (14035 or 14030)	2	Planned	Y, N	Y	Oncor	Resolved by the completion of the Dermott - Ennis Creek 138 kV line upgrade completed in Spring '15.		
ONCOR	East Levee Sw - West Netowrk	LN	138	2015	5, 6	DCKT West Levee Switch - 800/900 Network 138 kV	East Levee Switch - Reagan Street 138 kV (3410_A)	1	Planned	N	Discussion Item				Oncor believes this congestion occurs only when Normally Open Lomo Alto CB 015 is closed. East Levee - West Network is only a HITE if CB 015 is closed during the outage.
ONCOR	East Levee Sw Bus West	BUS	138	2015	11	Norwood Sw AXFMR1 345/138 kV	Amelia Street - UT SW Medical Center (3415)	2	Planned	N					
ONCOR	Elkton - Forney Sw	LN	345	2015	4	Tyler Grande to Martin Lake 345 kV	Elkton ACFMR3 345/138 kV	2	Planned	Y					
ONCOR	Exxon Means Tap - Andrew North	LN	138	2015	6	Key Sub - Willow Valley Switch 138 kV	Getty Vealmoor - Getty Vealmoor Tap 138 kV	1	Forced	N	Y	Oncor	Resolved by the upgrade of the Lamesa - Buzzard Draw 138 kV line rebuild completed in Fall '15.		
ONCOR	Gunsight Sw - Getty Vealmoor	LN	138	2015	6	Key Sub - Willow Valley Switch 138 kV	Big Spring Crmwd Tap - Big Spring Switch 69 kV	1	Planned	N	Y	Oncor	Resolved by the upgrade of the Lamesa - Buzzard Draw 138 kV line rebuild completed in Fall '15.		
ONCOR	Jewett - Singleton (240)	LN	345	2015	10	DCKT Gibbons Creek - Singleton 345 kV	Jewett - Singleton 345 kV	2	Planned	N					
ONCOR	Lake Creek Bus #1	BUS	138	2015	9	Waco Mm Mars 2 to Robinson (6) 138 KV	Elm Mott - Northcrest Tap 138kV	1, 2	Planned	N					

ONCOR	Lake Hubbard Bus #1	BUS	138	2015	5	DCKT Lake Hubbard to Centerville Road and Centerville Road Sw 138 kV	Lake Hubbard - Saint Augustine Tap 138 kV	2	Planned	N					
ONCOR	Lufkin Sw - Stryker Creek	LN	345	2015	10	Nacogdoches Se - Mt Enterprise 345 kV	Centerville I45 - Pleasant Springs (Hcec) 138kV	1	Forced	N	Y	Oncor	Same as row 116 Stryker Creek - Lufkin Sw.		
ONCOR	Lufkin Sw Auto #1	XF	345	2015	10	Nacogdoches Se - Mt Enterprise 345 kV	Centerville I45 - Pleasant Springs (Hcec) 138kV	1	Forced	N					
ONCOR	Martin Lake Bus #1	BUS	345	2015	4	DCKT Mt Enterprise to Trinidad and Martin Lake to Stryker Creek	Stryker Creek - Gresham Road Sw 138 kV	2	Planned	N					
ONCOR	Morgan Creek - Sun Sw	LN	138	2015	5	Dermott Switch Ax1hh (3)345/138 kV	China Grove Switch - Snyder 138 kV	1	Planned	N	Y	Oncor	Resolved by the completion of the Dermott - Ennis Creek 138 kV line upgrade completed in Spring '15. Also believe this congestion was caused by temporary configurations during the construction of that project.		
ONCOR	Morgan Creek Bus #1	BUS	138	2015	10	Willow Valley Switch to Westt Faraday 345 kV	Barber Lake Sw - Morgan Creek 138 kV (14030)	2	Planned	N	Y	Oncor	Resolved by the completion of the Dermott - Ennis Creek 138 kV line upgrade completed in Spring '15. Also believe this congestion was caused by temporary configurations during the construction of that project.		
ONCOR	Mountain Creek East Bus	BUS	138	2015	11, 12	Cedar Crest Sw - Mountain Creek 138 kV	Cedar Crest Sw - Oak Cliff South 138 kV (3160)	2	Planned	N					
ONCOR	Mountain Creek West Bus	BUS	138	2015	10	Irving Norwood to Norwood Sw 138 kV	Cedar Crest Sw - Oak Cliff South 138 kV (3150)	2	Planned	N					
ONCOR	Norwood Sw Auto #1	XF	345	2015	2	DCKT Norwood Sw to Mountain Creek and East Levee Sw	Reagan Street - Amelia Street 138 kV	2	Planned	N					
ONCOR	Norwood Sw Bus #1	BUS	345	2015	12	Watermill Sw to Sargent Road and West Levee Sw 345 kV	Norwood Sw AXFMR1 345/138 kV	2	Planned	Y					
ONCOR	Permian Basin - Wink Sub	LN	138	2015	6	Chevron Has - Wickett Whiting Oil 138 kV	Northward - Wink Sub 69 kV	1	Planned	N					
ONCOR	Royse Sw Auto #1	XF	345	2015	9	Royse Switch Axfrm3 345/138 KV	Forney Switch - Forney West 138kV	1	Planned	N					
ONCOR	Sherry Sw - ... - Poly America	LN	138	2015	5	Cedar Hill Sw AXFMR2 345/138 kV	Park Row - Sherry Sw (6325)	2	Planned	N	Y	Oncor	Resolved by completion of the Sherry - Cedar Hill upgrade project completed in May 2015		
ONCOR	Snyder - Sacroc	LN	138	2015	9	Dermott Switch Ax1hh (3)345/138 KV	Morgan Creek Ses - Sun Switch 138 kV	1	Planned	N	Y	Oncor	Resolved by the completion of the Dermott - Ennis Creek 138 kV line upgrade completed in Spring '15. Also believe this congestion was caused by temporary configurations during the construction of that project.		
ONCOR	Stryker Creek - Lufkin Sw	LN	345	2015	9	Nacogdoches Se to Mt Enterprise 345 KV	Centerville I45 - Pleasant Springs 138kV	1	Planned	N					

ONCOR	Temple Sw - Bell County East Sw	LN	345	2015	3	Navarro - Watermill Switch 345 kV	Big Brown - Richland Chambers 345 kV	1	Planned	N					
ONCOR	Valley SES Bus #2	BUS	138	2015	8	Valley South to Anna Sw and Farmersville Sw 345 kV	Pink Hills Pod - Payne Sw 138 kV	2	Planned	Y	Discussion Item				Confirm that this is for the Valley SES West Bus
ONCOR	Venus Sw Bus #1	BUS	345	2015	7	Limits Generation		2	Planned	N	Discussion Item				Confirm which bus at Venus Switch. (North or South)
ONCOR	Watermill Sw - Sargent Road	LN	345	2015	3	Topeka Termination - West Levee Switch 345 kV	Cedar Hill Switch - Mountain Creek 138 kV	1	Planned	N	Y	Oncor	Expected to be resolved by the completion of the Cedar Hill - Mountain Creek 138 kV line upgrade. Expected completion Fall '16.		
ONCOR	Watermill Sw - West Levee Sw	LN	345	2015	3	Topeka Termination - West Levee Switch 345 kV	Cedar Hill Switch - Mountain Creek 138 kV	1	Planned	N	Y	Oncor	Expected to be resolved by the completion of the Cedar Hill - Mountain Creek 138 kV line upgrade. Expected completion Fall '16.		